



Certificate of Compliance

Certificate: 80091613

Master Contract: 301183

Project: 80091613

Date Issued: 2022-02-02

Issued To: WISE Control Inc.
2022, Deogyong-daero, Giheung-gu,
Yongin-si, Gyeonggi-do, 17097
South Korea

Attention: Donghyun Kim

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: Jimmy Solanki
Jimmy Solanki



PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - Certified to US Standards

Ex eb IIC Gb;

Class I, Zone 1, AEx eb IIC Gb

The R810 series resistance temperature devices (RTDs) are typically used to measure internal temperatures of motors/generators. The R810 series Stator Winding RTDs are inserted in between the stator winding coils of the stator slots. Available with 3, 4, 6 and 8 wire options and are connected by means of flying leads.

Electrical Rating: Operating voltage (V) < 30V, measuring current = 0.2 – 5.0 mA and maximum measuring current = 5.0 mA. Service Temperature : -50 °C ~ 180 °C.