

TEST REPORT

1. Applicant

Name : WISE CONTROL Inc.
Address : 2022. Deogyong-daero, Giheung-gu, Yongin-si,
Gyeonggi-do, Korea

2. Products

Name : Temperature Sensor (Thermocouple & RTD)
Model/Type : ETR(R942)
Manufacturer : WISE CONTROL Inc.
Remark : -

3. Test Standard/Method : IEC 60529:2001, KS C IEC 60529:2006

4. Test Results : IP67 (Refer to document)

5. Use of Report : For Quality Control

6. Date of Application : 2013. 05. 27

7. Date of Issue : 2013. 05. 30

Tested by



Machinery Convergence Technology Center
Chang-ho Kim

Approved by



Machinery Convergence Technology Center
Leader Jun-gu Kang

The above test report is the accredited test results by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.

Korea Testing Laboratory



222-13, Guro3-Dong Guro-Gu Seoul, 152-718, Korea.
<http://www.ktl.re.kr>

Tel. : +82-2-860-1531
Fax. : +82-2-860-1549